



Pimpri Chinchwad Municipal Corporation
Pimpri , Pune – 411018.
Phone :- 020- 67331110/1120
Fax :- 020- 27425600
E-Mail :- commissioner@pcmcindia.gov.in
Web :- www.pcmcindia.gov.in

NO – ws/lab/955/2026

Date – 19/10/2026

To

The Principal,

The Shri Ram Universal School,

Kiwale, Pune.

Subject: Water sample Potability Certificate.

Drinking water sample provided by The Shri Ram Universal School, Kiwale, Pune on Date: 16/10/2026 was analysed for Chemical and Bacteriological analysis. As per the analysis reports no. ws /lab /947/2026 dated 17/10/2026 & ws /lab /951/2026 dated 17/10/2026 the water Samples are safe for drinking purpose.

The Bacteriological & chemical analysis reports are attached herewith.

Note-The water sample not drawn by this laboratory


CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Nigdi, Pune 44

PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER



No-WS/LAB/951 /2026.

Date - 17 / 10 /2026.

NAME - The Shri Ram Universal School. DATE OF EXAMINATION - 16 /10/2026.

ADDRESS - Kiwale, Pune.

SOURCE - Filter Water.

SR.NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUSION MPN/100ml		REMARK
			Coliforms	E.Coli	
1	Water Sample.	Nil	0/100ml	-	Potable.
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					


CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Nigdi, Pune 44

PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION



REPORT OF CHEMICAL EXAMINATION OF WATER

NAME - The Shri Ram Universal School.

No-WS/LAB/947/2026.

Date - 17/10/2026.

ADDRESS - Kiwale, Pune.

Date of Receipt - 16/10/2026.

SOURCE - Filter Water.

Date of Examination - 16/10/2026.

Sr.No.	Tests	I. S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N. T. U. Max	0.51 NTU.		
2	pH	6.5 to 8.5	7.01		
3	Total Hardness (as CaCO ₃)	200 mg/lit	20 mg/lit.		
4	Chloride	250 mg/lit	8 mg/lit.		
5	Calcium	75 mg/lit	4.80 mg/lit.		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY

CHIEF CHEMIST

WATER TREATMENT PLANT, NIGDI, PCMC

पिंपरी चिंचवड महानगरपालिका, पिंपरी - ४११ ०१८.

G. No. 1700113

सामान्य पोर्वती

दि. 16/10/2026

श्री. / मे. श्री राम युनिवर्सल स्कूल रा. किवळे

यांजकडून अक्षरी रूपये एक हजार पुकळो वहा अकत हपाणि नमुके
याबद्दल रोख / चेकने मिळाले. (तपासकी ९४९९९०)

हस्ते श्री राम शाळा (९५५५ ०४६०६२)

रु. ९९९०

लेखापाल

रोखपाल / लिपिक



The Shri Ram Universal School
Igniting Curiosity, Nurturing Creativity

To,

The Water Treatment Plant

Pimpri Chinchwad Municipal Corp.

Nigdi, Pune-44

Subject: - Issuance of Safe Drinking Water and sanitary Condition Certificate as per the CBSE norms for our school, The Shri Ram Universal School, Kiwale, Pune -412101

Dear sir


We, The Shri Ram Universal School, Kiwale, Pune, are a new school who adhere to the norms of CBSE. The school is situated at Survey no. 11/1/1 at kiwale (Mamurdi), Haveli, Pimpri-Chinchwad, Pune Maharashtra-412101

In this context, as per the norms of CBSE, a safe Drinking Water and Sanitary Condition Certificate is required from the respective City corporation.

Request you to let us know how to proceed and will be happy to provide any other information as may be necessary.


Warm Regards

For The Shri Ram Universal School, Kiwale, Pune -412101


Principal



The Shri Ram Universal School, Kiwale, Pune -412101


16/10/2020

012

9850249984